



ADDENDUM #5

Competitive Proposal RFP # 1959-20 Vacancy Prep

Original Notice of RFP Issued on: Wednesday, January 6, 2021

Original Response Due Date: Thursday, January 28, 2021 @ 2:00 pm

PROPOSAL DATE EXTENDED: THURSDAY, FEBRUARY 4, 2021 @ 2:00 PM

ADDED WALK THROUGH DATE: JANUARY 28, 2021 STARTING AT 8 A.M.

January 25, 2021

To All Prospective Respondents:

The purpose of this addendum is to:

1. PROVIDE ANSWERS TO QUESTIONS RAISED BY POTENTIAL RESPONDENTS
2. THE EXTENDED PROPSAL DUE DATE: **TO THURSDAY, FEBRUARY 4, 2021**
3. THIS IS A SECOND WALK-THROUGH: **JANUARY 28, 2021 STARTING AT 8 A.M.**

POTENTIAL RESPONDENT QUESTIONS AND ANSWERS:

QUESTION 1: Is HACH going to provide asbestos information?

ANSWER: . Asbestos containing material has been identified in the Taping (Joint) Compound, floor tile and mastic of some units at Betty Knox during prior maintenance and rehabilitation. Any vacant unit preparation activities which could disturb similar materials must be accompanied by applicable ACM testing and remediation. This ACM statement applies only to the units identified for vacant unit preparation at Betty Knox in

the Solicitation and should not be taken as a general statement as to the presence of ACM at any other Authority development.

- Please continue to monitor for additional addendums. Failure to acknowledge all amendments may lead to a non-responsive request.

All other terms of the solicitation remain the same.